



August 11, 2011

Carl J. Foreman
Director, Environmental Health & Safety
University of California, Davis
One Shields Avenue
Davis, CA 95616-8586

Re: Notice of Proposed Decision - Minor Title V Permit Modification F-00454-20

Dear Mr. Foreman:

Enclosed for your review and comment are the District's proposed revised Title V operating permit F-00454-20, Statement of Basis Addendum/Emission Evaluation and Authority to Construct (ATC) for University of California, Davis in Davis, CA.

This notification is given in accordance with District Rule 3.8, Section 409.2 for a minor Title V permit modification. The proposed revisions are necessary due to the pending issuance of ATC C-11-62, proposing the installation of five small natural gas fired low NOx boilers with a combined heat input of 2.25 MMBtu/hr.

ATC application C-11-62 has been processed in accordance with the Enhanced New Source Review requirements of District Rule 3.4, Section 404. Section 404.1 of District Rule 3.8, requires that upon the implementation of the ATC into a Permit to Operate, the University of California, Davis, request, in writing, that the District amend the Title V operating permit to incorporate the proposed modifications.

If you have any questions on this matter, please contact Nancy Fletcher at (530) 757-3656 or toll-free in the (530), (916), and (707) area codes at (800) 287-3650.

Sincerely,

Susan K. McLaughlin
Supervising Air Quality Engineer

Enclosures: Proposed Title V Operating Permit F-00454-20, Proposed Statement of Basis Addendum/Emission Evaluation and Proposed ATC C-11-62